

Our Ref: RW/M5354

19/02/2008

Donit Tesnit dd  
Cesta Komandanta Staneta 38  
S1 1215 Medvode  
Slovenia

Dear Sir

**WATER REGULATIONS ADVISORY SCHEME**  
**“ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920”**

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

**FIBRE**

**5075**

Doniflex G. Grey gasket material. For cold and hot water use up to 85°C.

Test Report: M 104031 / M 104185

**0706534**

**DONIT TESNIT DD**

An entry, as above, will accordingly be included in the Water Fittings Directory on-line, Part Two, under the section headed, “Materials which have passed full tests of effect on water quality”.

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings Directory on-line: this may be abbreviated to “Water Regulations Advisory Scheme - Approved Material” or “WRAS - Approved Material”. **Approval of this product does not signify the approval of its mechanical or physical properties for any use.**

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in June 2012.

Yours faithfully

*R. L. Williams*

Rebecca Williams  
Materials Approval  
Water Regulations Advisory Scheme

21 02 2008  
*AGS*  
*JF*