

Zvonko Majcen
Donit Tesnit dd
Cesta Komandanta Staneta 38
SI - Medvote
Slovenia

Dear Mr Majcen

TESNIT BAGL 3000 - DIRECTORY REFERENCE NUMBER 0403507

This listing will appear in the next edition of the Water Fittings and Materials Directory.


The Directory is available from:-

WRc plc
Unit 30
Fern Close
Pen-y-Fan Ind Estate
Oakdale
Gwent
NP1 4EH

Tel No: 01495 248454
Fax No : 01495 249234

Published twice annually in April and October. Single issue £22.00 + postage and packing, £22.00 + £3.50 P&P inside Europe and £22.00 + £7.00 outside Europe. Cheques made payable to WRc plc.

Yours sincerely



Chris Ramsey (Miss)
Materials Administrator
Water Regulations Advisory Scheme

Our Ref: CR/JC

10 May 2004

Donit Tesnit dd
Cesta Komandanta Staneta 38
SI - Medvote
Slovenia

Dear Sir

WATER REGULATIONS ADVISORY SCHEME
"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

FIBRE

5075

Tesnit BAGL 3000. Green/blue coloured gasket material. For cold water and hot water use up to 85°C. For use only as a jointing/gasket material having been tested at reduced surface area.

Test Report: M103287

0403507

DONIT TESNIT DD

An entry, as above, will accordingly be included in the Water Fittings and Materials Directory, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings and Materials Directory: this may be abbreviated to "Water Regulations Advisory Scheme - Approved Product" or "WRAS - Approved Product". **Approval of this product does not signify the approval of its mechanical or physical properties for any use.**

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in March 2009.

Yours faithfully



Chris Ramsey (Miss)
Materials Administrator
Water Regulations Advisory Scheme