

Our Ref: CR/JC

20 February 2006

Donit Tesnit D.D.
Cesta Komandanta Staneta 38
S1 - 1215 Medvode
Slovenia

Dear Sir

WATER REGULATIONS ADVISORY SCHEME
"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

FIBRE

5075

BA-U. Blue coloured compressed gasket material. For cold water and hot water use up to 85°C. For use only as a jointing/gasket material having been tested at reduced surface area to volume ratio.

Test Report: M103723/A

0512513

DONIT TESNIT DD

An entry, as above, will accordingly be included in the Water Fittings and Materials Directory, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings and Materials Directory: this may be abbreviated to "Water Regulations Advisory Scheme - Approved Product" or "WRAS - Approved Product". **Approval of this product does not signify the approval of its mechanical or physical properties for any use.**

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in December 2010.

Yours faithfully



Chris Ramsey (Miss)
Materials Administrator
Water Regulations Advisory Scheme

MATERIALS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY AND ARE USED IN THE MANUFACTURE OF WATER FITTINGS AND WATER INSTALLATIONS AND IN THEIR ASSEMBLY, CONNECTION, DISCONNECTION AND REPAIR.

The material or product referred to in this letter is suitable for contact with, and for the manufacture of components of water fittings for use in contact with water for domestic purposes. The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use. Certain products are approved in the full knowledge that for many plastic materials and natural and synthetic rubbers, variations in curing times and temperatures may have a significant effect on water quality. The right is reserved to require the testing of components made from any of these materials before listing those components if the scheme has any reason to believe that they differ from the materials originally tested and listed.

Entries in the Directory relating to components made from listed materials are included on the understanding that the components are made of precisely the same materials as the test samples without any modification and without the addition or substitution of any ingredients, and that, as applicable, the curing times and temperature shall be as nearly as possible those recommended by the manufacturers of the materials or products and used for the production of test samples.

In order to avoid their affecting water quality, materials must be allowed to cure at the correct temperature for the necessary length of time. This cannot always be achieved where materials are mixed on site, often in approximate proportions, and cured in situ often under cold, ill-ventilated conditions. Entries relating to products or products produced under properly controlled factory conditions, cannot be guaranteed to apply to site conditions.