



# DVGW-Baumusterprüfzertifikat

## DVGW type examination certificate

**DG-5126BN0490**

Registriernummer  
registration number

|   |  |
|---|--|
| <b>Anwendungsbereich</b><br><i>field of application</i>   | Produkte der Gasversorgung<br><i>products of gas supply</i>  |
| <b>Zertifikatinhaber</b><br><i>owner of certificate</i>   | DONIT TESNIT d.d.<br>Cesta komandanta Staneta 38, SLO-1215 Medvode   |
| <b>Vertreiber</b><br><i>distributor</i>                   | DONIT TESNIT d.d.<br>Cesta komandanta Staneta 38, SLO-1215 Medvode   |
| <b>Produktart</b><br><i>product category</i>              | greasing and sealing materials: Flat sealing materials for gas installation, with higher thermal resistance (5126)   |
| <b>Produktbezeichnung</b><br><i>product description</i>   | Flat sealing material on sythetic fibres basis for gas meter connections according to DIN 3376-1 (two pipes connection) and DIN 3376-2 (one pipe connection), higher thermal resistant |
| <b>Modell</b><br><i>model</i>                             | Tesnit BA-55   |
| <b>Prüfberichte</b><br><i>test reports</i>                | laboratory control test: 08/130/5126/01 from 21.07.2008 (EBI)  |
| <b>Prüfgrundlagen</b><br><i>basis of type examination</i> | DVGW VP 401 (01.10.1998)   |

**Ablaufdatum / AZ** 16.08.2011 / 08-0547-GNV  
*date of expiry / file no.*

30.07.2008 Rie A-1/2  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle  
*date, issued by, sheet, head of certification body*

DVGW CERT GmbH - von der Deutschen Akkreditierungsstelle Technik (DATech) in der TGA GmbH akkreditiert für die Konformitätsbewertung von Produkten der Gas- und Wasserversorgung

DVGW CERT GmbH - accredited by Deutsche Akkreditierungsstelle Technik (DATech) in the TGA GmbH for conformity assessment of products of gas and water supply



DVGW CERT GmbH  
Josef-Wirmer-Straße 1-3  
53123 Bonn

Telefon: +49 228 91 88-888  
Telefax: +49 228 91 88-993  
eMail: info@dvw-cert.com

DAT-ZE-009/96-02

| <b>Typ</b><br><i>type</i> | <b>Technische Daten</b><br><i>technical data</i> | <b>Bemerkungen</b><br><i>remarks</i> |
|---------------------------|--|--------------------------------------|
| Tesnit BA-55              | maximum operating pressure: 1 bar                |                                      |

**zertifizierte Bauteile / Werkstoffe**  
*certified components*

| <b>Registr.-Nr.</b><br><i>registration no.</i> | <b>Bauteil (Produktart)</b><br><i>component</i> | <b>Modell/Typ</b><br><i>model/type</i> | <b>Hersteller</b><br><i>manufacturer</i> |
|--|---|--|--|
| NG-5123BN0398                                  | Flat sealing materials on synthetic fiber basis | TESNIT BA-55/TESNIT BA-55              | DONIT TESNIT d.d.                        |

**Verwendungshinweise / Bemerkungen**  
*hints of utilization / remarks*

area of application: for gas meter connections according to DIN 3376-1 (two pipes connection) and DIN 3376-2 (one pipe connection)